

3.13 “CE” Indoor Unit: Failure of Combination (Between Indoor unit PC Board and Fan PC Board)

Remote Controller Display	
Applicable Models	FXMQ40~125P
Method of Malfunction Detection	Conduct open line detection with PC board for fan (A2P) using indoor PC board (A1P).
Malfunction Decision Conditions	When the communication data of PC board for fan (A2P) is determined as incorrect.
Supposed Causes	<p>The possible causes are:</p> <ul style="list-style-type: none"> ■ Malfunction of PC board for fan (A2P). ■ Connection defect of capacity setting adapter. ■ Setting mistake on site.

Troubleshooting

