

3.6 Abnormal Power Supply Voltage

Remote Controller Display	
Applicable Models	FXMQ40~125P
Method of Malfunction Detection	Detect malfunction checking the input voltage of fan motor.
Malfunction Decision Conditions	When the input voltage of fan motor is 150V and below, or 386V and above.
Supposed Causes	<p>The possible causes are:</p> <ul style="list-style-type: none"> ■ Power-supply voltage malfunction. ■ Connection defect on signal line. ■ Wiring defect. ■ Instantaneous blackout, others.

Troubleshooting

Caution Be sure to turn off power switch before connect or disconnect connector, or parts damage may be occurred.

